

CONTINUOUS TENSION /  
COMPRESSION POST IN  
END OF SHEAR WALL PER  
PLAN.

**NOTE:**

IF HOLDOWN IS ATTACHED TO POST  
PRIOR TO SIP INSTALLATION, ONLY  
REMOVAL OF THE FOAM WILL BE  
REQUIRED AND THERE IS NO REASON TO  
REMOVE OSB FACING AS SHOWN HERE.  
SEE PBS-306A

(2) 2X SPLINE BLOCKING FOR  
OSB ATTACHMENT. SEE PBS-205

FILL CAVITY WITH RIGID OR  
EXPANDABLE FOAM, REPLACE OSB.

FASTENERS PER  
HOLDOWN  
MANUFACTURER.

HOLDOWN  
ANCHOR PER PLAN

CONCRETE WALL OR SLAB

BOTTOM PLATE

TREATED SILL PLATE

N.T.S.

Rev: 12/10/2021

PBS-306

HDU TYPE HOLDOWN

