STUDY SUMMARY MOISTURE NO. 102

Exterior Foundation Wall Insulation.

The impact of moisture absorption on the performance of polystyrene foam insulations used for below grade applications is an important design consideration. It has been scientifically proven that water absorption into polystyrene foam insulations will diminish R-values.

This Study Summary provides the results of a research project conducted in 1988 by the Energy Division of The Minnesota Department of Public Service. The project report is entitled "A Survey of Minnesota Home Exterior Foundation Wall Insulation: Moisture Content and Thermal Performance".

Two expanded polystyrene and fourteen extruded polystyrene (XPS) insulation samples were removed 6-24 inches below grade from the foundations of Minnesota homes. The objective of the study was to survey the performance of below grade insulation 2-5 years after initial installation.

Summary of 1988 Study Test Results¹

| Material | Age (Years) | Thickness (Inches) | Density (pcf) |
|-------------------------|----------------|-----------------------|------------------|
| Expanded Polystyrene | 6.50 | 1.39 | 1.27 |
| XPS | 2.86 | 2.00 | 2.01 |

| Material | Moisture Content (Volume %) | R-value (°F.ft².h/Btu) | |
|-------------------------|-----------------------------------|---------------------------|---------|
| | | per inch | % Loss2 |
| Expanded Polystyrene | 0.49 | 3.55 | 1.4 |
| XPS | 0.47 | 4.91 | 1.9 |

¹ Average of samples.

The results indicate that the below grade moisture absorption of the expanded polystyrene and XPS samples are comparable. It is interesting to note that the expanded polystyrene samples exhibited similar water absorption results even though they were installed for more than twice the length of time. These results suggest very clearly that short term laboratory tests of water absorption for expanded polystyrene and XPS do not necessarily reflect the long term below grade performance of these materials.






FOAM FACTS:

Below Grade Water Absorption

WATER ABSORPTION AND R-VALUE RETENTION¹



¹ Testing was conducted by Energy Division of The Minnesota Department of



²Based upon R-value of 3.6 for Expanded polystyrene and 5.0 for XPS.